

Date Issued	June 03, 2026	Status	Closed
Provider Name	KID'S WORLD LEARNING CENTER		
Provider ID	011512327		
Provider Address	2220 6th St, Brookings, SD 57006, USA		
Provider Contact	Robin Rice		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:39

For family day care providers, unused electrical outlets must have an outlet plug cover, have a tamper-resistant cover, or be made inaccessible to a child.

For center and school-age programs, unused electrical outlets must have a self-closing outlet cover or tamper-resistant cover.

Summary of Non-Compliance Finding:

Program using manual closing tamper resistant power strips that are accessible to children and were not closed when not in use.

Corrections to be Made:

For center and school-age programs, unused electrical outlets must have a self-closing outlet cover or tamper-resistant cover.

Corrections Made:

Program manually closed the unused outlets on power strips at time of inspection.

Anticipated Completion Date:
May 25, 2026

Date Completed:
May 11, 2026

Compliance Plan Action #2

Administrative Rule:

67:42:17:33

A provider shall meet the following requirements regarding bathrooms:

- (1) Bathroom facilities must be easily accessible by children and providers;
- (2) Hot water for faucets normally used by children in care may not exceed one hundred twenty degrees Fahrenheit;
- (3) Toilets and hand sinks must be kept clean and in good repair; and
- (4) For child care centers and school-age programs:

- (a) All bathrooms must have natural or mechanical ventilation;
- (b) Separate bathrooms must be available for males and females;
- (c) Ratios for toilet and hand sinks must align with the minimum standards for plumbing and plumbing systems published by the plumbing commission.

Except in a family day care, hand sinks must be in the same room, or an unobstructed room adjacent to the diaper changing area. A handwashing sink used after diapering and toileting may not be used for food preparation.

Summary of Non-Compliance Finding:

At time of inspection, water temperature at a sink being used by children to wash their hands was at 157 degrees Fahrenheit.

Corrections to be Made:

Program shall meet requirements as outlined in ARSD 67:42:17:33.

Corrections Made:

Verification received that water temperature has been adjusted to meeting licensing requirements.

Anticipated Completion Date:

June 03, 2026


Date Completed:

May 12, 2026

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Robin Rice

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

June 03, 2026

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Ambuer Jaacks

Printed Name of DSS Staff



5/29/2026, 4:48:19 PM

Signature of DSS Staff:

May 29, 2026

Date