

Date Issued	May 28, 2026	Status	Closed
Provider Name	CULTIVATE CHILDCARE NURSERYCARE		
Provider ID	018043012		
Provider Address	4825 S Hosta Ave, Sioux Falls, SD 57110, USA		
Provider Contact	Darbi Nelson		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

During the inspection, it was observed that the exit lights in the kitchen and above the south door leading to the playground did not illuminate when tested.

Corrections to be Made:

The provider will ensure that all exit lights illuminate.

Corrections Made:

Verification of compliance was received.

Anticipated Completion Date:
June 11, 2026

Date Completed:
June 08, 2026

Compliance Plan Action #2

Administrative Rule:

67:42:17:44

All toxic or hazardous substances must be:

- (1) Inaccessible to children;
- (2) Used according to manufacturer's instructions;
- (3) Stored in the original or other labeled container; and
- (4) Disposed of according to manufacturer recommendations.

Bio-contaminants must be handled and disposed of properly.

Soiled diapers must be changed promptly, in a designated area, on a non-porous surface. The diaper changing area must be clean and disinfected with a sanitizing solution approved by the department. Soiled diapers must be kept in a leakproof, nonabsorbent container that is covered with a tight-fitting lid.

Summary of Non-Compliance Finding:

During inspection, it was observed that sanitizer bottles throughout the program contained insufficient bleach solution when tested.

Corrections to be Made:

The provider will ensure that all sanitizer bottles are properly mixed and maintained at the required bleach concentration and that an appropriate disinfecting solution is consistently available for use.

Corrections Made:

Verification that the bleach concentrations and their respective uses are appropriate for disinfection was received.


Anticipated Completion Date:
June 11, 2026

Date Completed:
May 26, 2026

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Bri McCarty

Printed Name of Provider/Agency Contact



May 28, 2026

Signature of Provider/Agency Contact

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Morgan Giraldo

Printed Name of DSS Staff



5/26/2026, 11:56:53 AM

Signature of DSS Staff:

May 26, 2026

Date