



- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

**Summary of Non-Compliance Finding:**

The emergency light at the west exit failed during testing.

**Corrections to be Made:**

The program will send photos of the repaired working exit light to the Office of Licensing and Accreditation.

**Corrections Made:**

The program sent photos of the repaired working exit light to the Office of Licensing and Accreditation.

**Anticipated Completion Date:**

June 25, 2026


**Date Completed:**

June 10, 2026

**Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.**

Belinda Feekes

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

May 28, 2026

Date

**The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.**

Teri Pieters

Printed Name of DSS Staff



6/2/2026, 1:18:27 PM

Signature of DSS Staff:

June 02, 2026

Date