

Date Issued	May 11, 2026	Status	Closed
Provider Name	Cozy Corner Daycare		
Provider ID	1777316595		
Provider Address	405 Broadway Ave, Valley Springs, SD 57068, USA		
Provider Contact	Daniel Sebit		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

A power strip was plugged into a lower outlet that was accessible to children. Additionally, the portable fire extinguisher has not been inspected annually by a qualified service technician.

Corrections to be Made:

Electrical systems need to be used properly, including not overloading extension cords. Portable fire extinguishers should be inspected annually by a qualified service technician.

Corrections Made:

The power strip was removed completely. Additionally, the portable fire extinguisher was inspected by a qualified service technician.

Anticipated Completion Date:
June 01, 2026

Date Completed:
May 11, 2026

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Ahmitara Alwal
Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

May 11, 2026
Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Brooke Flemmer
Printed Name of DSS Staff



5/11/2026, 10:22:16 AM
Signature of DSS Staff:

May 11, 2026
Date