

Date Issued June 24, 2026 Status Closed

Provider Name Our Little Treasures Early Learning Center
Provider ID 1724955634
Provider Address 5502 Oak St, Black Hawk, SD 57718, USA
Provider Contact Erika Huemiller

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

Exit sign at the front door does not illuminate when tested.

Corrections to be Made:

Program will repair the exit sign at the front door to ensure it illuminates then submit verification to the Office of Licensing & Accreditation.

Corrections Made:

Program repaired the exit sign at front door to ensure it illuminated and submitted verification to the Office of Licensing & Accreditation.

Anticipated Completion Date:
June 30, 2026

Date Completed:
June 24, 2026

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Erika Huemiller

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact


June 24, 2026

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Andrea Neff

Printed Name of DSS Staff



6/16/2026, 12:40:46 PM

Signature of DSS Staff:

June 16, 2026

Date