

|                  |                                          |        |        |
|------------------|------------------------------------------|--------|--------|
| Date Issued      | June 17, 2026                            | Status | Closed |
| Provider Name    | LIL' BUG'S LEARNING CENTER               |        |        |
| Provider ID      | 018042957                                |        |        |
| Provider Address | 501 W 4th St, Dell Rapids, SD 57022, USA |        |        |
| Provider Contact | Heidi Anderson                           |        |        |

The items listed below are those that the provider was not in compliance with at the time of the inspection.

### Compliance Plan Action #1

**Administrative Rule:**

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

**Summary of Non-Compliance Finding:**

During inspection, documentation of an annual fire system alarm inspection was not available.

**Corrections to be Made:**

The provider will obtain documentation of the annual fire alarm system by June 10, 2026.

**Corrections Made:**

Verification of compliance was received on June 25, 2026.

**Anticipated Completion Date:**

**Date Completed:**

**Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.**

Heidi Anderson

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

June 12, 2026

Date

**The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.**

Morgan Giraldo

Printed Name of DSS Staff



5/22/2026, 9:56:15 AM

Signature of DSS Staff:

Date