

COMPLIANCE PLAN
OFFICE OF LICENSING & ACCREDITATION



Date Issued	June 23, 2026	Status	In Process
Provider Name	LAURA WILDER ELEMENTARY CLC		
Provider ID	018043144		
Provider Address	2300 S Lyndale Ave, Sioux Falls, SD 57105, USA		
Provider Contact	Saundra Larson		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:32

All walls, ceilings, floors, and equipment must be easily cleanable, kept clean, and in good repair. Heating and cooling systems must maintain a temperature between sixty-five degrees Fahrenheit and seventy-five degrees Fahrenheit. For a child care center and school-age program, all heating and cooling systems must be inspected annually, by a certified technician.

Food preparation areas, including tables and countertops, must be made of a smooth, nonporous material, kept clean and sanitized, be free of cracks, and be in good repair. Center and school-age programs, in which more than twenty children are cared for, must provide a ventilation hood over all cooking areas. The hood must be appropriate for the type of appliance and intended use, as required in § 61:15:01:01.

Summary of Non-Compliance Finding:

The provider did not have documentation showing that the heating and cooling systems were inspected annually by a certified technician.

Corrections to be Made:

The provider will submit documentation to the Office of Licensing and Accreditation showing that the heating and cooling systems were inspected.

Corrections Made:

The provider submitted documentation to the Office of Licensing and Accreditation showing that the heating and cooling systems were inspected.

Anticipated Completion Date:
July 23, 2026

Date Completed:
June 25, 2026

Compliance Plan Action #2

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

During the inspection, the exit lights on the second floor and in the stairwells did not light when the test button was pressed.

Corrections to be Made:

The program will provide documentation to the Office of Licensing and Accreditation demonstrating that all exit signs are functioning properly and illuminate when tested.

Corrections Made:

Anticipated Completion Date:
July 23, 2026

Date Completed:

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Saundra Larson

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact


June 23, 2026

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Teri Pieters

Printed Name of DSS Staff

A handwritten signature in black ink that reads "Teri Pieters". The signature is written in a cursive style with a large initial "T" and "P".

6/23/2026, 8:05:31 AM

Signature of DSS Staff:

June 23, 2026

Date