

Date Issued	July 28, 2026	Status	Closed
Provider Name	LITTLE WINGS PRESCHOOL		
Provider ID	018043096		
Provider Address	1208 W 51st St Ste 3, Sioux Falls, SD 57105, USA		
Provider Contact	Mal Wehrkamp		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

The program did not have documentation of the fire extinguisher being inspected annually by a certified technician.
The program did not have a carbon monoxide detector installed.

Corrections to be Made:

The program will provide documentation to the Office of Licensing and Accreditation for the annual inspection of the fire extinguisher by a certified technician.
The program will install a carbon monoxide detector and provide a picture to the Office of Licensing and Accreditation.

Corrections Made:

The program provided documentation to the Office of Licensing and Accreditation for the annual inspection of the fire extinguisher by a certified technician.

The program installed a carbon monoxide detector and provided a picture to the Office of Licensing and Accreditation.

Anticipated Completion Date:

August 07, 2026

Date Completed:

July 21, 2026

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Mel Wehrkamp

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

July 07, 2026

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Teri Pieters

Printed Name of DSS Staff



7/17/2026, 1:46:19 PM

Signature of DSS Staff:

July 17, 2026

Date