

Date Issued	August 07, 2026	Status	Closed
Provider Name	LOLA - CENTER		
Provider ID	011102577		
Provider Address	719 E Grand Crossing, Mobridge, SD 57601, USA		
Provider Contact	Emily Moser		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

The west exit has boxes stored that restrict the door from fully opening and restricts the width of egress to less than 36".

Corrections to be Made:

The boxes stored in the west exit egress path need to be removed.

Corrections Made:

The boxes stored in the west exit egress path have been removed.

Anticipated Completion Date:
August 07, 2026

Date Completed:
July 25, 2026

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Lake Oahe Learning Academy - Center
Printed Name of Provider/Agency Contact




Signature of Provider/Agency Contact

August 07, 2026
Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Julie Hermansen
Printed Name of DSS Staff



6/16/2026, 9:35:26 AM
Signature of DSS Staff:

June 16, 2026
Date