

Date Issued	August 21, 2026	Status	In Process
Provider Name	Spink County Daycare Center		
Provider ID	140494090		
Provider Address	25 W 6th Ave, Redfield, SD 57469, USA		
Provider Contact	Gianna Schieffer		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:35

Playgrounds for all child care settings must be safe, in good repair, and free of debris, trash, and weeds. Playground equipment must be installed according to the manufacturer's instructions and maintained in good repair.

For a center program, a fence that measures at least four feet high is required around the center's outdoor play space.

For a family day care or school-age program, a fence that measures at least forty-two inches high may be required to separate the outdoor play space, if the department determines a body of water, vehicular traffic, or other hazard poses a risk of injury or death to a child.

Summary of Non-Compliance Finding:

A fence around the outdoor play area has not yet been installed but is scheduled for installation.

Corrections to be Made:

A fence at least four feet high must be installed around the outdoor play area. Until the fence is installed, the program will ensure children remain under active supervision at all times and required staff-to-child ratios are maintained. Providers will position themselves to maintain continuous sight and sound supervision of all children and will ensure children do not leave the designated play area.

Corrections Made:

Anticipated Completion Date:
September 14, 2026

Date Completed:

Compliance Plan Action #2

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

The daycare facility does not currently have a carbon monoxide detector.

Corrections to be Made:

A carbon monoxide detector must be installed according to the manufacturer's instructions in the daycare facility.

Corrections Made:

The provider installed a carbon monoxide detector according to the manufacturers instructions in the daycare facility.

Anticipated Completion Date:

September 14, 2026

Date Completed:

August 18, 2026

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Gianna Schieffer Spink County Daycare

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact


August 17, 2026

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Julie Hermansen

Printed Name of DSS Staff



8/17/2026, 11:25:51 AM

Signature of DSS Staff:

August 17, 2026

Date
