

Date Issued August 07, 2026 Status Closed

Provider Name REDEEMING ROOTS
Provider ID 014512626
Provider Address 1101 Broadway Ave Suite 123, Yankton, SD 57078, USA
Provider Contact Koty Frick

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:37

Center and school-age programs operating outside of a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:05 and 61:15:06. School-age programs operating in a school building shall follow applicable construction and fire safety requirements, as outlined in chapters 61:15:01, 61:15:02, and 61:15:07.

A family day care home must have the following fire safety measures in place:

- (1) A working smoke detector must be located on each level of the home;
- (2) A fully charged, portable fire extinguisher, with a minimum 2A rating, as identified on the extinguisher label, must be kept in or within fifteen feet of the kitchen or food preparation area;
- (3) A carbon monoxide detector must be installed, according to the manufacturer's instructions, if a fuel burning appliance is present in the home;
- (4) Each level of the home must have at least two remote exits that shall remain clear of obstructions. One of these exits must be a standard-sized door, and the other may be either a standard-sized door or an unobstructed, operable window, having at least five square feet of openable space, with a minimum width of twenty inches and a minimum height of twenty-four inches; and
- (5) Whenever a portable space heater, a wood burning stove, or a fireplace is in use, the heater, stove, or fireplace must be inaccessible to children.

Summary of Non-Compliance Finding:

Documentation of an inspection of the fire alarm completed within the past year was not available. The fire extinguishers were not inspected within the past year. The fire alarm system layout for the addition does not match the approved floorplan.

Corrections to be Made:

Inspections need to be completed as required and an updated floorplan with accurate fire alarm system layout details must be submitted.

Corrections Made:

Verification was received that all issues were corrected.

Anticipated Completion Date:
August 14, 2026

Date Completed:
August 07, 2026

Compliance Plan Action #2

Administrative Rule:

67:42:17:32

All walls, ceilings, floors, and equipment must be easily cleanable, kept clean, and in good repair. Heating and cooling systems must maintain a temperature between sixty-five degrees Fahrenheit and seventy-five degrees Fahrenheit. For a child care center and school-age program, all heating and cooling systems must be inspected annually, by a certified technician.

Food preparation areas, including tables and countertops, must be made of a smooth, nonporous material, kept clean and sanitized, be free of cracks, and be in good repair. Center and school-age programs, in which more than twenty children are cared for, must provide a ventilation hood over all cooking areas. The hood must be appropriate for the type of appliance and intended use, as required in § 61:15:01:01.

Summary of Non-Compliance Finding:

Verification of heating and cooling system inspections completed by a certified technician within the past year were not available.

Corrections to be Made:

The system inspections must be completed as required.

Corrections Made:

Verification of completed inspections was received.

Anticipated Completion Date:
August 14, 2026

Date Completed:
August 26, 2026

Compliance Plan Action #3

Administrative Rule:

67:42:17:44

All toxic or hazardous substances must be:

- (1) Inaccessible to children;
- (2) Used according to manufacturer's instructions;
- (3) Stored in the original or other labeled container; and
- (4) Disposed of according to manufacturer recommendations.

Bio-contaminants must be handled and disposed of properly.

Soiled diapers must be changed promptly, in a designated area, on a non-porous surface. The diaper changing area must be clean and disinfected with a sanitizing solution approved by the department. Soiled diapers must be kept in a

leakproof, nonabsorbent container that is covered with a tight-fitting lid.

Summary of Non-Compliance Finding:

Cleaning supplies are stored in an unlocked cupboard under the sink in the bathroom in the new space to be used.

Corrections to be Made:

The cupboard must be locked or the supplies moved so that they are inaccessible to children.

Corrections Made:

Verification was received that the items were moved to an inaccessible location.

Anticipated Completion Date:

August 07, 2026

Date Completed:

August 06, 2026

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Koty Frick

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

August 03, 2026

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Deb Bigge

Printed Name of DSS Staff



Signature of DSS Staff:

August 03, 2026

Date

8/3/2026, 3:51:26 PM