COMPLIANCE PLAN
OFFICE OF LICENSING & ACCREDITATION

South Dakota Department of Social Services

Date Issued	September 18, 2026	Status	Closed

Provider Name	Human Service Agency
Provider ID	ACC1029
Provider Address	123 19th St NE, Watertown, SD 57201
Provider Contact	Kari Johnston

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:62:09:02

Each building the center owns, rents, or leases must comply with applicable fire safety standards, as set forth in the 2012 edition of the NFPA 101 Life Safety Code. An automatic sprinkler system is not required in an existing facility, unless significant renovation or remodeling occurs. An existing automatic sprinkler system must remain in service.

New construction, renovations, additions, and changes of space must comply with NFPA 101 Life Safety Code, 2012 edition. Each facility must also comply with the building construction standards of the International Building Code, 2012 edition.

Summary of Non-Compliance Finding:

The ceiling and vent in the kitchen of Serenity Hills were covered in lint and in need of cleaning.

Corrections to be Made:

Human Service Agency must clean the ceiling and vents in the kitchen of Serenity Hills.

Corrections Made:

Human Service Agency contracts with a company to routinely complete this.

Anticipated Completion Date: **Date Completed:**

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Kari Johnston
Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

September 18, 2026
Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Printed Name of DSS Staff

Signature of DSS Staff:

Date