

Date Issued	October 22, 2026	Status	Closed
Provider Name	McCook Central After School Program		
Provider ID	289784270		
Provider Address	200 E Essex Ave, Salem, SD 57058, USA		
Provider Contact	Masey Pechholt		

The items listed below are those that the provider was not in compliance with at the time of the inspection.

Compliance Plan Action #1

Administrative Rule:

67:42:17:39

For family day care providers, unused electrical outlets must have an outlet plug cover, have a tamper-resistant cover, or be made inaccessible to a child.

For center and school-age programs, unused electrical outlets must have a self-closing outlet cover or tamper-resistant cover.

Summary of Non-Compliance Finding:

The outlets in room 114 do not have self closing or tamper resistant outlet covers.

Corrections to be Made:

Unused electrical outlets must have a self-closing or a tamper resistant cover.

Corrections Made:

Verification of correction was received.

Anticipated Completion Date:

October 29, 2026

Date Completed:

October 05, 2026

Your signature below certifies you have read and understand the non-compliance findings and agree to make corrections to be compliant with the identified administrative rules.

Jessica Bridges

Printed Name of Provider/Agency Contact



Signature of Provider/Agency Contact

October 01, 2026

Date

The Department of Social Services, Office of Licensing and Accreditation has reviewed and accepted the above plan.

Deb Bigge

Printed Name of DSS Staff



9/30/2026, 4:33:59 PM

Signature of DSS Staff:

September 30, 2026

Date