SOUTH DAKOTA DEPARTMENT OF HEALTH

LICENSURE & SAFETY: Health Protection | Licensure & Certification | Medical Cannabis
ACCREDITATION & REPORTING: Vital Records | Health Data & Reporting
Accreditation & Quality | Legal

RECEIVED
APR 08 2024
SD DOH-OLC

DATE: March 27, 2024

TO: Dr. Tom Stanage, Thomas.Stanage@lcbhs.net
Lewis & Clark Behavioral Health Services Residential Substance Use Treatment
1028 Walnut Street
Yankton, SD 57078

FROM: Cassie Deffenbaugh, MSN, BSN, RN, Administrator
Department of Health Office of Licensure and Certification
600 East Capitol Avenue
Pierre, SD 57501

RE: Compliance Survey March 13, 2024

BY: Travis Nelsen, Senior Health Facility Surveyor

Cc: Muriel J. Nelson
Program Manager
Office of Licensing and Accreditation
Department of Social Services

Code Standards: Administrative Rules of South Dakota (ARSD) 67:62 Mental Health, 67:61:10 Substance Use Disorders, and 44:78 Inpatient Chemical Dependency
National Fire Protection Association Code 101 Life Safety Code, 2000 Edition, Chapters 1through10 inclusive and Chapters 33 and 39.

Memorandum of Understanding:
A compliance survey for the above-referenced regulations and codes was conducted on March 13, 2024. The purpose of this survey was to evaluate the operation to determine compliance with the above ARSDs and LSC references.

We request that you provide this office with your plan of correction stating the completion date for the corrections, the corrective action you have taken, or the plan of correction that you intend to make. Please type your plan of correction on this document and submit it to the following email addresses: DOHOLCPoC@state.sd.us and Travis.Nelsen@state.sd.us. **The plan must be submitted to our office by April 6, 2024.**

Inpatient Chemical Dependency Treatment Facility – License: 32
1000 W 4th St (Crisis care, 3.2D & 3.7), Yankton

1. The cross-corridor doors in the south hall would not latch when closed. Leased space from the hospital. Hospital maintenance was responsible for ensuring those doors close and latch. Please work with them to make sure those doors close and latch.

Vermillion (200 West Main)

2. The basement bathroom needs a paper towel dispenser to protect the supply of paper towels from contamination from wet hands.

1028 Walnut (Three Story), Yankton

3. The building was found in compliance.

1012 Walnut, Yankton (Administration – two story house)
Not used by clients.

Lake Andes (Connecting Point)
Not inspected, provider has been evicted from the current premises and will be looking for a new location.

301 Capital, Yankton (Impact)

4. The North stairwell does not have self-closing doors to protect the exit corridor from smoke passage. The doors in the stairwell on second and third floor should have self-closing devices to prevent the passage of smoke.

Date all deficiencies will be corrected by:

Plan of correction:

1. On 3/27/24 at 2:30pm Avera Maintenance came and worked on the fire doors in the long hallway. Avera Maintenance reported that the panic hardware needed to be lubed. It was done and the door is latching.
2. The paper towel dispenser was installed in 200 West Main, Vermillion basement bathroom – 4/5/2024.
3. N/A
4. The north stairwell door has had self-closing hinges installed – 4/5/2024.