SOUTH DAKOTA DEPARTMENT OF HEALTH

LICENSURE & SAFETY: Health Protection | Licensure & Certification | Medical Cannabis
ACCREDITATION & REPORTING: Vital Records | Health Data & Reporting
Accreditation & Quality | Legal

Date: February 22, 2024

To: Marianne Riley mariley@threeriverscounseling.com
Three Rivers Mental Health
11 East 4th Street
PO Box 447
Lemmon, SD 57638

From: Cassie Deffenbaugh, MSN, BSN, RN, Administrator
Department of Health
Division of Licensure and Accreditation
Office of Licensure and Certification
600 East Capitol Avenue
Pierre, SD 57501

Re: Compliance Survey February 14-15, 2024

By: Travis Nelsen, Senior Health Facility Surveyor

Facility type: Mental Health business occupancy

STANDARDS: Administrative Rules of South Dakota (ARSD) 67:62 Mental Health
National Fire Protection Association Code 101 Life Safety Code (LSC), 2012 Edition, Chapters 1-10 inclusive and Chapter 33

CC: Muriel J. Nelson, Program Manager
Office of Licensing and Accreditation
Department of Social Services

A compliance survey for the above-referenced codes and standards was conducted on February 14-15, 2024. The purpose of this survey was to evaluate the operation to determine compliance with the above ARSDs and LSC references.

We request that you provide this office with your plan of correction stating the completion date for the corrections, the corrective action you have taken, or the plan of correction that you intend to make. Please type your plan of correction on this document and submit it to the following email addresses: **DOHOLCPoC@state.sd.us** and **Travis.Nelsen@state.sd.us**. **The plan must be submitted to our office by March 3, 2024.**

Faith – Outreach Clinic
112 N. 2nd Avenue W.

1. No deficiencies noted.

Bison – Outreach Clinic
105 W. Main

2. No deficiencies noted.

Lemmon
11 E. 4th Street

3. Two emergency lights would not light when tested.

McLaughlin – Outreach Clinic
305 2nd Ave. W.

4. The fire extinguisher at the north EXIT was last inspected in May 2021. Another annual inspection should be scheduled.

Timber Lake – Outreach Clinic
711 Main Street ("The Junction" building)

5. No deficiencies noted.

Eagle Butte – Outreach Clinic
404 S. Spiel Ct.

6. The fire extinguisher was last inspected in 2021. Another annual inspection should be scheduled.

Correction date: 2/23/2024

Plan of corrections: Ordered two emergency lights for the Lemmon office. Scheduled an inspection on

2/27/2024 for the fire extinguishers in Eagle Butte and McLaughlin.