

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Hand in Hand Community Daycare**

City: **Miller**

Provider Number: **000097047**

Inspector: **Carrie Lewis**

Date of Inspection: **10/19/2022**

Time of Inspection: **10:11 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

12. Are exits and exit corridors maintained in a safe manner? 61:15:05:05 NOTE: Exits can't pass through storeroom, bathroom, kitchen; corridor & aisle widths of 36 inches; exits cannot be obstructed.

<p>Corrections To Be Made:</p> <p>Observed numerous boxes of toilets from remodeling bathrooms, in the exit corridor going out the east door.</p> <p>Verification was received showing the boxes were removed from the east exit corridor.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">11/02/2022</td> <td style="text-align: center;">11/08/2022</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	11/02/2022	11/08/2022
Suggested Completion Date:	Actual Completion Date:				
11/02/2022	11/08/2022				

B. ENVIRONMENTAL HEALTH

50. Is the heating and cooling system maintained and inspected annually? 67:42:11:12

<p>Corrections To Be Made:</p> <p>Verification of heating and cooling inspections completed within the past year could not be located at the time of inspection.</p> <p>An inspection of the heating and cooling systems must be completed annually.</p> <p>Verification of the annual heating and cooling inspection was received,</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">11/02/2022</td> <td style="text-align: center;">12/07/2022</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	11/02/2022	12/07/2022
Suggested Completion Date:	Actual Completion Date:				
11/02/2022	12/07/2022				

Clover Herdman

Provider Signature

10/19/2022

Date

Carrie Lewis

Inspector Signature

10/19/2022

Date