

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Hand in Hand Community Day Care**

City: **Miller**

Provider Number: **000097047**

Inspector: **Neal Cruse**

Date of Inspection: **10/04/2023**

Time of Inspection: **9:17 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. Environmental Health

34. Is the hot water temperature at hand washing sinks used by children maintained at 120 degrees F or lower? 67:42:17:33

<p>Corrections To Be Made:</p> <p>Water temperature needs to be turned down to maximum of 120F.</p> <p>The hot water temperature at hand washing sinks used by children must be maintained at 120 degrees F or lower.</p> <p>Verification received that the hot water was turned down.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">10/11/2023</td> <td style="text-align: center;">10/10/2023</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	10/11/2023	10/10/2023
Suggested Completion Date:	Actual Completion Date:				
10/11/2023	10/10/2023				

Clover Herman

10/04/2023

Provider Signature

Date

Neal Cruse

10/04/2023

Inspector Signature

Date