

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Bethesda Learning Academy**

City: **Aberdeen**

Provider Number: **000097106**

Inspector: **Clint Rux**

Date of Inspection: **08/15/2022**

Time of Inspection: **9:30 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

10. If providing care for children under 5 years of age, are there self-closing, or tamper resistant childproof electrical covers on all outlets? 67:42:11:10

<p>Corrections To Be Made:</p> <p>The outlets in the dining area of the South wing did not have self-closing, or tamper resistant covers on the outlets.</p> <p>All the outlets in the daycare area need self-closing or tamper resistant childproof electrical covers on all outlets.</p> <p>Correction: The Provider installed self-closing outlets in the dining area of the South wing of the daycare.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">09/15/2022</td> <td style="text-align: center;">09/08/2022</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	09/15/2022	09/08/2022
Suggested Completion Date:	Actual Completion Date:				
09/15/2022	09/08/2022				

Robin Loebis

Provider Signature

08/15/2022

Date

Clint Rux

Inspector Signature

08/15/2022

Date