

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Rapid City Childrens Center**

City: **Rapid City**

Provider Number: **000097111**

Inspector: **Robert Weig**

Date of Inspection: **03/11/2024**

Time of Inspection: **8:46 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. Environmental Health

34. Is the hot water temperature at hand washing sinks used by children maintained at 120 degrees F or lower? 67:42:17:33

<p>Corrections To Be Made:</p> <p>Hot Water temperature in gym bathroom measured at 130F.</p> <p>Hot water temperature can not exceed 120 degrees F.</p> <p>*Provider emailed a statement that the water temperature was turned down to 115 degrees F.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%; border: none;">Suggested Completion Date:</td> <td style="width: 50%; border: none;">Actual Completion Date:</td> </tr> <tr> <td style="border: none;">03/25/2024</td> <td style="border: none;">03/18/2024</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	03/25/2024	03/18/2024
Suggested Completion Date:	Actual Completion Date:				
03/25/2024	03/18/2024				

Jodi Richter

03/11/2024

Provider Signature

Date

Robert Weig

03/11/2024

Inspector Signature

Date