

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Stepping Stones Child Care**

City: **Pierre**

Provider Number: **010274633**

Inspector: **Chad Wrightson**

Date of Inspection: **11/21/2023**

Time of Inspection: **3:35 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

21. Are portable fire extinguishers charged, operable, and inspected annually by a qualified service technician? 61:15:05:10 NOTE: Minimum 2A rated on each level. No more than 75 feet travel distance to an extinguisher. One near food preparation.

Corrections To Be Made:

A current inspection is needed for the fire extinguishers.

Providers will have a portable fire extinguisher charged, operable, and inspected annually by a qualified service technician.

Verification that the provider has a charged, operable, and inspected fire extinguisher has been received.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

12/01/2023

Actual
Completion
Date:

12/22/2023

Status: **Corrected**

Kristin Vermundson

Provider Signature

11/21/2023

Date

Chad Wrightson

Inspector Signature

11/21/2023

Date