

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Centerville OST Program**

City: **Centerville**

Provider Number: **010501773**

Inspector: **Stacy Wildermuth**

Date of Inspection: **10/02/2024**

Time of Inspection: **3:15 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

23. Is there a carbon monoxide detector installed according to the manufacturer's directions if there is a furnace or appliances utilizing fossil fuels such as propane, natural, gas, etc.? 61:15:01:01

Corrections To Be Made:

Carbon monoxide detector is not available and is needed because the facility uses natural gas.

Verification was received that a carbon monoxide detector was installed.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

10/08/2024

Actual
Completion
Date:

10/09/2024

Status: **Corrected**

B. Environmental Health

38. Do providers and children wash their hands with soap, before preparing food or beverages, eating, handling food, or feeding a child, and after changing a diaper, using the toilet, helping a child use a toilet, or coming into contact with bodily fluid? 67:42:17:25

Corrections To Be Made:

The same sink is being used for hand washing after using the bathroom and for handwashing before handling food.

Verification was received that a sink in the food storage area is now being used for handwashing before handling food.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

10/02/2024

Actual
Completion
Date:

10/09/2024

Status: **Corrected**

Liz Peterson

Provider Signature

10/02/2024

Date

Stacy Wildermuth

Inspector Signature

10/02/2024

Date