

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Rural America Initiatives**

City: **Rapid City**

Provider Number: **010601775**

Inspector: **Robert Weig**

Date of Inspection: **08/22/2024**

Time of Inspection: **7:48 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

23. Is there a carbon monoxide detector installed according to the manufacturer's directions if there is a furnace or appliances utilizing fossil fuels such as propane, natural, gas, etc.? 61:15:01:01

Corrections To Be Made:	Agency Action:	
Program did not have carbon monoxide detectors.	Compliance Plan	
Program will need to install carbon monoxide detectors.	Suggested Completion Date:	Actual Completion Date:
Correction: Program installed carbon monoxide detectors.	09/01/2024	09/04/2024
	Status: Corrected	

Anne Reddy

Provider Signature

08/22/2024

Date

Robert Weig

Inspector Signature

08/22/2024

Date