

Facility Safety Inspection

Fire & Life Safety / Environmental Health

Before & After School Center - Non-School Location

Compliance Plan

Provider's Name: **First Baptist Childrens Center**

City: **Sioux Falls**

Provider Number: **010602017**

Inspector: **Todd Lowe**

Date of Inspection: **03/15/2023**

Time of Inspection: **4:02 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

11. Are exits and exit corridors maintained in a safe manner? 61:15:05:05 NOTE: Exits can't pass through storeroom, bathroom, kitchen; corridor & aisle widths of 36 inches; exits cannot be obstructed.

Corrections To Be Made:

The magnetic hold, double fire doors off the Fellowship Hall 2 had children's backpacks in front of it that would not allow the door to close should an activation of the fire alarm occur.

All exits must be able to pass through and not be obstructed by objects.

Correction: The backpacks were moved, and staff were retrained to make sure that the exits are not obstructed.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

03/15/2023

Actual
Completion
Date:

03/15/2023

Status: **Corrected Immediately**

Sheena Christensen

Provider Signature

03/15/2023

Date

Todd Lowe

Inspector Signature

03/15/2023

Date