

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **First Baptist Childrens Center
OST**

City: **Sioux Falls**

Provider Number: **010602017**

Inspector: **Todd Lowe**

Date of Inspection: **05/06/2024**

Time of Inspection: **4:43 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

4. In Licensed Programs caring for 21 or More Children - Is a fire alarm system installed in the building hard wired and operable? 61:15:05:08 NOTE: Manual pull stations, audible alarms inside and out. Smoke detectors are in stairwells, corridors, lounges, recreation and sleeping areas.

Corrections To Be Made:

A stack of old doors leaned against the pull station in the basement mechanical room, making it inaccessible.

Manual pull stations must have a clear path.

The path to the pull station has been cleared by the provider immediately.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

05/13/2024

Actual
Completion
Date:

05/13/2024

Status: **Corrected**

18. Are exits and exit corridors maintained in a safe manner? 61:15:05:05; 61:15:06:05 NOTE: Exits can't pass through storeroom, bathroom, kitchen; corridor & aisle widths maintained at 36 inches or more; exits cannot be obstructed.

Corrections To Be Made:

Exit doors and corridors were obstructed in the lower-level fellowship hall #2 and the main gym double doors.

All Exit corridors and doors must remain passable.

The provider cleared all exits and will ensure that the exit corridors and doors always remain unblocked.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

05/08/2024

Actual
Completion
Date:

05/06/2024

Status: **Corrected**

21. Are portable fire extinguishers charged, operable, and inspected annually by a qualified service technician? 61:15:05:10 NOTE: Minimum 2A rated on each level. No more than 75 feet travel distance to an extinguisher. One near food preparation.

Corrections To Be Made:

Documentation for an annual inspection for the fire extinguisher in the fellowship hall was not available at the time of the inspection.

All portable fire extinguishers must be charged, operable, and inspected annually by a qualified service technician.

Documentation for a current inspection for the fire extinguisher which was conducted by a qualified service technician was submitted to OLA.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

Actual
Completion
Date:

05/16/2024

05/13/2024

Status: **Corrected**

Sheena Christensen

Provider Signature

05/06/2024

Date

Todd Lowe

Inspector Signature

05/06/2024

Date