

# Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Peace Lutheran Early Childhood Center**

City: **Brookings**

Provider Number: **010604129**

Inspector: **Charles Schmidt**

Date of Inspection: **04/22/2024**

Time of Inspection: **9:48 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. Fire and Life Safety

23. Is there a carbon monoxide detector installed according to the manufacturer's directions if there is a furnace or appliances utilizing fossil fuels such as propane, natural, gas, etc.? 61:15:01:01

|  |                            |                         |
|--|----------------------------|-------------------------|
| Corrections To Be Made:  | Agency Action:             |                         |
| <b>Building has a furnace and/or appliances that utilize fossil fuels and there is not a carbon monoxide detector installed.</b>                     | <b>Compliance Plan</b>     |                         |
| <b>A carbon monoxide detector must be installed according to manufacturers directions if there is a furnace or appliance utilizing fossil fuels.</b> | Suggested Completion Date: | Actual Completion Date: |
| <b>Correction: Verification received that program has installed a carbon monoxide detector according to manufacturers directions</b>                 | <b>05/31/2024</b>          | <b>05/03/2024</b>       |
|  | Status: <b>Corrected</b>   |                         |

## B. Environmental Health

50. Are the following hazards inaccessible to children: fire arms; pellet guns; BB guns; cap guns; ammunition; matches; lighters; tobacco products; items capable of being pulled or tipped onto a child such as a TV, shelf, dresser; sharp objects such as knives and scissors; small objects the size of a half-dollar or smaller that could present a choking hazard; or strangulation hazards such as dangling cords? 67:42:17:38

Corrections To Be Made:

**Hot wax melting air freshener was sitting on a shelf in the classroom and was accessible to children at time of inspection.**

**All hazards must be in accessible to children.**

**Correction: Wax warmer was moved immediately at time of inspection.**

Agency Action:

**Compliance Plan**

Suggested  
Completion  
Date:

Actual  
Completion  
Date:

**04/22/2024**

**04/22/2024**

Status: **Corrected Immediately**

**Stacy**

Provider Signature

**04/22/2024**

Date

**Charles Schmidt**

Inspector Signature

**04/22/2024**

Date