

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Crow Creek Childcare**

City: **Fort Thompson**

Provider Number: **010604407**

Inspector: **Russ Lauritsen**

Date of Inspection: **10/10/2023**

Time of Inspection: **1:55 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

13. In Licensed Programs caring for 21 or More Children - If domestic cooking equipment is installed, is a ventilating hood and duct provided and vented to the outside of the building to handle grease-laden vapors? 67:42:17:32

Corrections To Be Made:	Agency Action:	
Vent hood system needs installed.	Compliance Plan	
The program will install a ventilating hood and duct which is vented to the outside of the building to handle grease-laden vapors.	Suggested Completion Date:	Actual Completion Date:
The program requested additional time to secure funding to have the vent hood installed in the kitchen.	05/31/2024	01/03/2024
	Status: Corrected	

Donna Voice

Provider Signature

10/10/2023

Date

Russ Lauritsen

Inspector Signature

10/10/2023

Date