

Family Day Care Inspection Compliance Plan

Provider's Name: **Tara Mettler**

City: **Summerset**

Provider Number: **010605230**

Inspector: **Andrea Neff**

Date of Inspection: **03/29/2023**

Time of Inspection: **10:50 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

C. Health & Safety Features of the Home - Indoor Environmental Observations

75. Is there an operating smoke detector with audible alarm located on each level of the home (regardless if level is used for care of children or not)? 67:42:03:11.02

Corrections To Be Made:

Smoke detector in hallway had a faint alarm and smoke detector in the living did not work.

Provider will need to replace both smoke detectors.

Correction: Provider installed new smoke detectors.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

04/12/2023

Actual
Completion
Date:

04/17/2023

Status: **Corrected**

Tara Mettler

Provider Signature

03/29/2023

Date

Andrea Neff

Inspector Signature

03/29/2023

Date