

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Sicangu Oyate Cinkala
Waunspe Oti**

City: **Rosebud**

Provider Number: **010605243**

Inspector: **Russ Lauritsen**

Date of Inspection: **03/02/2023**

Time of Inspection: **1:59 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

11. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

Corrections To Be Made:

Batteries are needed for exit signs for when power goes out.

Provider will need to put batteries in exit signs.

Correction: Provider put batteries in exit signs.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

03/16/2023

Actual
Completion
Date:

03/27/2023

Status: **Corrected**

Angela Lowe

Provider Signature

03/02/2023

Date

Russ Lauritsen

Inspector Signature

03/02/2023

Date