

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **EmBe - South Childcare**

City: **Sioux Falls**

Provider Number: **010605399**

Inspector: **Sarah Boese**

Date of Inspection: **03/29/2024**

Time of Inspection: **11:52 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

16. Do all unused electrical outlets have self-closing or tamper resistant childproof electrical covers?
67:42:17:39 NOTE: Outlet plug covers are not permitted.

Corrections To Be Made:

Two outlet covers located in the gym are no longer self-closing and need to be fixed or replaced.

All unused electrical outlets must have self-closing or temper resistant childproof electrical covers.

The outlets were replaced with tamper resistant outlets.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

04/12/2024

Actual
Completion
Date:

04/03/2024

Status: **Corrected**

17. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05; 61:15:06:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

Corrections To Be Made:

Multiple exit sign emergency lights were not functioning - the kitchen north door, lunch room door, gym west door and north door, and locker room emergency lights above the door leading to the gym.

Exit signs must be interior or exterior illuminated or self-luminous.

The exit signs are functioning.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

04/12/2024

Actual
Completion
Date:

04/03/2024

Status: **Corrected**

B. Environmental Health

40. Are handwashing sinks used for diaper changing different than the sinks used for food or bottle prep?
67:42:17:33

Corrections To Be Made:	Agency Action:	
There were sippy cups in the handwashing sink in the Blossoms Room.	Compliance Plan	
Handwashing sinks used for diaper changing must be different than the sinks used for food or bottle prep.	Suggested Completion Date:	Actual Completion Date:
The program placed a sign to designate the handwashing sink and will keep it empty.	04/05/2024	04/03/2024
	Status: Corrected	

Sarah Meagher
Provider Signature

03/29/2024
Date

Sarah Boese
Inspector Signature

03/29/2024
Date