

# Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Enemy Swim Day School OST**

City: **Waubay**

Provider Number: **010605432**

Inspector: **Eric Anderson**

Date of Inspection: **02/29/2024**

Time of Inspection: **12:32 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. Fire and Life Safety

16. Do all unused electrical outlets have self-closing or tamper resistant childproof electrical covers?  
67:42:17:39 NOTE: Outlet plug covers are not permitted.

### Corrections To Be Made:

**The electrical outlets are not self-closing or tamper resistant and childproof. The facility is working on a plan to get them changed.**

**The unused electrical outlets need to be self-closing or tamper resistant childproof.**

**Since the electrical outlets were not replaced by the agreed upon date, a corrective action plan was implemented to allow the program additional time to complete the project.**

### Agency Action:

#### Corrective Action Plan

Suggested  
Completion  
Date:

Actual  
Completion  
Date:

**01/31/2025**

Status: **Pending**

**Rebecca Dargatz**

Provider Signature

**02/29/2024**

Date

**Eric Anderson**

Inspector Signature

**02/29/2024**

Date