

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Growing Dreams Learning Center**

City: **Freeman**

Provider Number: **010605489**

Inspector: **Carrie Lewis**

Date of Inspection: **05/12/2023**

Time of Inspection: **9:29 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

10. If providing care for children under 5 years of age, are there self-closing, or tamper resistant childproof electrical covers on all outlets? 67:42:11:10

Corrections To Be Made:

In the infant room, no electrical covers were on the outlets at time of inspection.

Verification was received that unused outlets were covered.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

05/26/2023

Actual
Completion
Date:

05/18/2023

Status: **Corrected**

20. NEW PROGRAMS: Are all requirements identified in the floor plan review letter issued by the Fire Marshall's Office completed? Does facility layout match the approved floor plan? 67:42:10:18

Corrections To Be Made:

In the southwest room, there was a deadbolt lock on the door at time of inspection.

Verification was received that the lock was removed.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

05/26/2023

Actual
Completion
Date:

05/18/2023

Status: **Corrected**

B. ENVIRONMENTAL HEALTH

50. Is the heating and cooling system maintained and inspected annually? 67:42:11:12

Corrections To Be Made:	Agency Action:	
No documentation for the heating and cooling system was available at this time of inspection.	Compliance Plan	
The heating and cooling system must be inspected annually.	Suggested Completion Date:	Actual Completion Date:
Verification of a completed inspection for the heating and cooling system was recieved.	05/12/2023	06/23/2023
	Status: Corrected	

Hannah Guthrie

Provider Signature

05/12/2023

Date

Carrie Lewis

Inspector Signature

05/12/2023

Date