

Facility Safety Inspection

Fire & Life Safety / Environmental Health

Before & After School Center - School Location

Compliance Plan

Provider's Name: **Totally Kids - Worthing**

City: **Worthing**

Provider Number: **010605570**

Inspector: **Michael Czmowski**

Date of Inspection: **10/24/2022**

Time of Inspection: **5:14 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

3. Is the fire alarm system operable? 61:15:05:08

<p>Corrections To Be Made:</p> <p>Observed fire alarm to have a trouble light indicating issues within the smoke detectors. The normal green light is also illuminated along with the yellow trouble. Seek guidance from facility managers on how to fix the issue.</p> <p>The fire alarm system must be operable.</p> <p>Correction: The smoke detectors have been fixed.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">11/23/2022</td> <td style="text-align: center;">12/12/2022</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	11/23/2022	12/12/2022
Suggested Completion Date:	Actual Completion Date:				
11/23/2022	12/12/2022				

B. ENVIRONMENTAL HEALTH

17. Is the heating and cooling system maintained and inspected annually? 67:42:11:12

Corrections To Be Made:

Annual inspection not available at time of inspection.

The heating and cooling system must be maintained and inspected annually

Correction: A copy of the current heating and cooling system inspection was received.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

Actual
Completion
Date:

11/23/2022

11/23/2022

Status: **Corrected**

Marissa Schanzenbach

Provider Signature

10/24/2022

Date

Michael Czmowski

Inspector Signature

10/24/2022

Date