

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Totally Kids - Worthing**

City: **Worthing**

Provider Number: **010605570**

Inspector: **Sarah Boese**

Date of Inspection: **11/11/2024**

Time of Inspection: **3:17 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

4. In Licensed Programs caring for 21 or More Children - Is a fire alarm system installed in the building hard wired and operable? 61:15:05:08 NOTE: Manual pull stations, audible alarms inside and out. Smoke detectors are in stairwells, corridors, lounges, recreation and sleeping areas.

<p>Corrections To Be Made:</p> <p>The fire alarm trouble light message was present at the time of the inspection.</p> <p>The fire alarm system must be operable.</p> <p>Correction: The director provided evidence that the fire alarm was inspected, and the system is operable.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">11/22/2024</td> <td style="text-align: center;">11/18/2024</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	11/22/2024	11/18/2024
Suggested Completion Date:	Actual Completion Date:				
11/22/2024	11/18/2024				

Eve Bunkers

Provider Signature

11/11/2024

Date

Sarah Boese

Inspector Signature

11/11/2024

Date