

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Abiding Savior Under Christ's Care**

City: **Sioux Falls**

Provider Number: **010605802**

Inspector: **Sarah Boese**

Date of Inspection: **05/31/2024**

Time of Inspection: **12:53 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

5. In Licensed Programs caring for 21 or More Children - Is a fire alarm system inspected and serviced annually by a qualified service technician? 61:15:01:01

<p>Corrections To Be Made:</p> <p>The last inspection of the fire alarm was in April of 2023.</p> <p>A qualified service technician will inspect the fire alarm system annually.</p> <p>The provider has provided verification showing that the fire alarm underwent service and inspection on April 2, 2024..</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">06/13/2024</td> <td style="text-align: center;">06/04/2024</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	06/13/2024	06/04/2024
Suggested Completion Date:	Actual Completion Date:				
06/13/2024	06/04/2024				

23. Is there a carbon monoxide detector installed according to the manufacturer's directions if there is a furnace or appliances utilizing fossil fuels such as propane, natural, gas, etc.? 61:15:01:01

<p>Corrections To Be Made:</p> <p>There is not a carbon monoxide detector in the building.</p> <p>If a furnace or appliances utilize fossil fuels such as propane, natural gas, etc., a carbon monoxide detector must be installed according to the manufacturer's directions.</p> <p>The provider installed a carbon monoxide detector.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">06/13/2024</td> <td style="text-align: center;">06/11/2024</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	06/13/2024	06/11/2024
Suggested Completion Date:	Actual Completion Date:				
06/13/2024	06/11/2024				

B. Environmental Health

48. Is the heating and cooling system maintained and inspected annually by a certified technician?
67:42:17:32

Corrections To Be Made:	Agency Action:	
The inspection verification for the heating and cooling system could not be found during the visit.	Compliance Plan	
The heating and cooling system must undergo annual maintenance and inspection by a certified technician.	Suggested Completion Date:	Actual Completion Date:
The provider provided verification indicating that the heating and cooling system was inspected by a certified technician.	06/13/2024	06/04/2024
	Status: Corrected	

Rayna Lowe

Provider Signature

05/31/2024

Date

Sarah Boese

Inspector Signature

05/31/2024

Date