

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Childrens Care Corner**

City: **Howard**

Provider Number: **010605880**

Inspector: **Neal Cruse**

Date of Inspection: **06/05/2024**

Time of Inspection: **9:44 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

16. Do all unused electrical outlets have self-closing or tamper resistant childproof electrical covers?
67:42:17:39 NOTE: Outlet plug covers are not permitted.

Corrections To Be Made:

There are outlets in the facility that do not have self-closing covers.

Covers are needed on all unused outlets.

Self-closing outlet covers were installed.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

06/30/2024

Actual
Completion
Date:

06/18/2024

Status: **Corrected**

19. In storage rooms, are combustible materials maintained at least 2 feet below the ceiling or 18 Inches below sprinkler head deflectors? 61:15:01:01

Corrections To Be Made:

Combustible materials are stored within 2 feet of the ceiling in the storage closet.

Storage must be maintained at least 2 feet below the ceiling.

The combustible materials were moved.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

06/06/2024

Actual
Completion
Date:

06/18/2024

Status: **Corrected**

B. Environmental Health

34. Is the hot water temperature at hand washing sinks used by children maintained at 120 degrees F or lower? 67:42:17:33

Corrections To Be Made:

The hot water temperature was measured at over 120 degrees F during the inspection.

The hot water temperature must be maintained at 120 degrees F or cooler.

The hot water temperature was adjusted and verified to be at less than 120 degrees F.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

06/15/2024

Actual
Completion
Date:

08/01/2024

Status: **Corrected**

Abby Kramer

Provider Signature

06/05/2024

Date

Neal Cruse

Inspector Signature

06/05/2024

Date