

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Becker's Bright Beginnings**

City: **Humboldt**

Provider Number: **010605938**

Inspector: **Todd Lowe**

Date of Inspection: **07/16/2024**

Time of Inspection: **10:09 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

20. Is electrical system being used properly? 61:15:01:01 NOTE: Check for overloads or frayed extension cords.

Corrections To Be Made:

The electrical cord to the TV was being pinched when the door is shut, causing cord damage, and posing a fire risk.

The electrical system must be used properly.

The cord was re-routed, so it is not being pinched when the door is shut.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

07/16/2024

Actual
Completion
Date:

07/16/2024

Status: **Corrected Immediately**

23. Is there a carbon monoxide detector installed according to the manufacturer's directions if there is a furnace or appliances utilizing fossil fuels such as propane, natural, gas, etc.? 61:15:01:01

Corrections To Be Made:

There was not a carbon monoxide detector present.

There must be a carbon monoxide detector installed according to the manufacturer's directions.

The provider installed a carbon monoxide detector.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

07/16/2024

Actual
Completion
Date:

07/25/2024

Status: **Corrected**

Amy Becker

Provider Signature

07/16/2024

Date

Todd Lowe

Inspector Signature

07/16/2024

Date