

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Our House Childcare LLC**

City: **Fort Pierre**

Provider Number: **010610997**

Inspector: **Chad Wrightson**

Date of Inspection: **08/16/2022**

Time of Inspection: **11:20 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

11. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

Corrections To Be Made:

The emergency exit lights above the south back door does not illuminate when tested.

The emergency exit light must be fixed or replaced.

Correction: The emergency lights above the south back door have been replaced.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

09/16/2022

Actual
Completion
Date:

10/03/2022

Status: **Corrected**

Angie Anderson

Provider Signature

08/16/2022

Date

Chad Wrightson

Inspector Signature

08/16/2022

Date