

Family Day Care Inspection Compliance Plan

Provider's Name: **Elizabeth Harris**

City: **Pierre**

Provider Number: **010611484**

Inspector: **Neal Cruse**

Date of Inspection: **05/09/2023**

Time of Inspection: **3:07 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

C. Health & Safety Features of the Home - Indoor Environmental Observations

69. Is the hot water temperature at hand washing sinks maintained at 120 degrees or lower?
67:42:03:11.05

Corrections To Be Made:

Water temperature tested at 140F.

The hot water at hand washing sink must be maintained at 120 degrees or lower.

Verification was received that a scald guard valve was installed on the hand washing sink and the water was at the correct temperature.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

05/30/2023

Actual
Completion
Date:

05/16/2023

Status: **Corrected**

Elizabeth Harris

Provider Signature

05/09/2023

Date

Neal Cruse

Inspector Signature

05/09/2023

Date