

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Wee Wolves Daycare**

City: **Wilmot**

Provider Number: **011102287**

Inspector: **Eric Anderson**

Date of Inspection: **03/14/2023**

Time of Inspection: **10:29 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

9. In storage rooms, are combustible materials maintained at least 2 feet below the ceiling or 18 Inches below sprinkler head deflectors? 67:42:10:18

<p>Corrections To Be Made:</p> <p>Items are stored too close to the ceiling in the storage rooms.</p> <p>Combustible items need to be stored at least 2 feet below the ceiling or 18 inches below sprinkler head deflectors.</p> <p>Correction: The storage items were moved immediately during the inspection.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">03/14/2023</td> <td style="text-align: center;">03/14/2023</td> </tr> </table> <p>Status: Corrected Immediately</p>	Suggested Completion Date:	Actual Completion Date:	03/14/2023	03/14/2023
Suggested Completion Date:	Actual Completion Date:				
03/14/2023	03/14/2023				

Jennifer DeGreef

03/14/2023

Provider Signature

Date

Eric Anderson

03/14/2023

Inspector Signature

Date