

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Westside After School Program (WASP)** City: **Sisseton**

Provider Number: **011102381**

Inspector: **Eric Anderson**

Date of Inspection: **03/04/2024**

Time of Inspection: **3:17 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

16. Do all unused electrical outlets have self-closing or tamper resistant childproof electrical covers?
67:42:17:39 NOTE: Outlet plug covers are not permitted.

Corrections To Be Made:	Agency Action:	
Several outlets are not self-closing.	Compliance Plan	
All unused electrical outlets need to have self-closing or tamper resistant childproof electrical covers.	Suggested Completion Date:	Actual Completion Date:
Correction: The Provider requested more time to install self-closing electrical outlet covers.	07/31/2024	05/14/2024
	Status: Corrected	

Alicia Finnesand

Provider Signature

03/04/2024

Date

Eric Anderson

Inspector Signature

03/04/2024

Date