

# Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Westside Preschool Program**

City: **Sisseton**

Provider Number: **011102433**

Inspector: **Eric Anderson**

Date of Inspection: **03/04/2024**

Time of Inspection: **2:05 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. Fire and Life Safety

16. Do all unused electrical outlets have self-closing or tamper resistant childproof electrical covers?  
67:42:17:39 NOTE: Outlet plug covers are not permitted.

<p>Corrections To Be Made:</p> <p><b>A couple of the electrical outlets are not self-closing.</b></p> <p><b>All unused electrical outlets need self-closing or tamper resistant childproof covers.</b></p> <p><b>Correction: Self-closing covers were installed on the electrical outlets that needed them.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%; border: none;">Suggested Completion Date:</td> <td style="width: 50%; border: none;">Actual Completion Date:</td> </tr> <tr> <td style="border: none;"><b>03/25/2024</b></td> <td style="border: none;"><b>04/29/2024</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>03/25/2024</b>	<b>04/29/2024</b>
Suggested Completion Date:	Actual Completion Date:				
<b>03/25/2024</b>	<b>04/29/2024</b>				

**Kara Schultz**

Provider Signature

**03/04/2024**

Date

**Eric Anderson**

Inspector Signature

**03/04/2024**

Date