

# Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Sprouts Community Daycare**

City: **Summit**

Provider Number: **011102493**

Inspector: **Eric Anderson**

Date of Inspection: **04/27/2023**

Time of Inspection: **10:57 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## B. ENVIRONMENTAL HEALTH

50. Is the heating and cooling system maintained and inspected annually? 67:42:11:12

Corrections To Be Made:

**The heating and cooling system was last inspected on 9/9/2021.**

**The heating and cooling system needs to be inspected annually.**

**Correction: The heating and cooling system was inspected by a service agent.**

Agency Action:

**Compliance Plan**

Suggested  
Completion  
Date:

**05/18/2023**

Actual  
Completion  
Date:

**06/26/2023**

Status: **Corrected**

**Emily Lane**

Provider Signature

**04/27/2023**

Date

**Eric Anderson**

Inspector Signature

**04/27/2023**

Date