

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Just Kidding Childcare Center Inc.**

City: **Aberdeen**

Provider Number: **011102509**

Inspector: **Clint Rux**

Date of Inspection: **08/17/2022**

Time of Inspection: **9:35 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

18. Are portable fire extinguishers charged and operable? 61:15:05:10 NOTE: Minimum 2A rated on each level. No more than 75 feet travel distance to an extinguisher. One near food preparation.

Corrections To Be Made:

Fire extinguishers were last inspected in January 2021.

The fire extinguishers need to be inspected annually.

Correction: The fire extinguishers were inspected on August 29, 2022.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

09/17/2022

Actual
Completion
Date:

08/29/2022

Status: **Corrected**

Adwoa Street

Provider Signature

08/17/2022

Date

Clint Rux

Inspector Signature

08/17/2022

Date