

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Just Kidding Childcare Center Inc**

City: **Aberdeen**

Provider Number: **011102509**

Inspector: **Clint Rux**

Date of Inspection: **07/16/2024**

Time of Inspection: **11:00 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

21. Are portable fire extinguishers charged, operable, and inspected annually by a qualified service technician? 61:15:05:10 NOTE: Minimum 2A rated on each level. No more than 75 feet travel distance to an extinguisher. One near food preparation.

<p>Corrections To Be Made:</p> <p>The fire extinguishers in the building were last inspected in August of 2022. The fire extinguisher by the storage room had the pin pulled, had been used and was no operational.</p> <p>All fire extinguishers need to be inspected annually by a certified agency.</p> <p>Correction: The fire extinguishers have been inspected by a service technician.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">08/15/2024</td> <td style="text-align: center;">08/06/2024</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	08/15/2024	08/06/2024
Suggested Completion Date:	Actual Completion Date:				
08/15/2024	08/06/2024				

23. Is there a carbon monoxide detector installed according to the manufacturer's directions if there is a furnace or appliances utilizing fossil fuels such as propane, natural, gas, etc.? 61:15:01:01

<p>Corrections To Be Made:</p> <p>A carbon monoxide detector was not installed in the daycare facility.</p> <p>A carbon monoxide detector must be installed according to the manufacturers directions.</p> <p>Correction: A carbon monoxide detector was installed according to the manufacturers directions.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">08/01/2024</td> <td style="text-align: center;">08/01/2024</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	08/01/2024	08/01/2024
Suggested Completion Date:	Actual Completion Date:				
08/01/2024	08/01/2024				

B. Environmental Health

49. Are all walls, ceilings, floors, and equipment easily cleanable, kept clean and in good repair?
67:42:17:32

Corrections To Be Made:	Agency Action:	
The wall in the coatroom where there used to be a door was not painted and was bare sheetrock.	Compliance Plan	
All walls need to be easily cleanable and in good repair.	Suggested Completion Date:	Actual Completion Date:
Correction: The wall in the coatroom was painted to cover the bare sheetrock.	08/01/2024	08/01/2024
	Status: Corrected	

Adowa Street

Provider Signature

07/16/2024

Date

Clint Rux

Inspector Signature

07/16/2024

Date