

# Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Helping Hands Childcare**

City: **Aberdeen**

Provider Number: **011102542**

Inspector: **Clint Rux**

Date of Inspection: **05/30/2023**

Time of Inspection: **2:50 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

6. If providing care for children under 5 years of age, are there self-closing, or tamper resistant childproof electrical covers on all outlets? 67:42:11:10

<p>Corrections To Be Made:</p> <p><b>Some of the self-closing outlet covers are no longer closing and remaining in a position that the plug is open.</b></p> <p><b>All the electrical outlets need to be self-closing or tamper resistant.</b></p> <p><b>Correction: The outlets were replaced with new self-closing outlets.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;"><b>06/15/2023</b></td> <td style="text-align: center;"><b>07/31/2023</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>06/15/2023</b>	<b>07/31/2023</b>
Suggested Completion Date:	Actual Completion Date:				
<b>06/15/2023</b>	<b>07/31/2023</b>				

**Madelein Gould**

**05/30/2023**

**Clint Rux**

**05/30/2023**

Provider Signature

Date

Inspector Signature

Date