

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **LOLA - Upper Elementary**

City: **Mobridge**

Provider Number: **011102576**

Inspector: **Clint Rux**

Date of Inspection: **08/06/2024**

Time of Inspection: **3:45 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

16. Do all unused electrical outlets have self-closing or tamper resistant childproof electrical covers?
67:42:17:39 NOTE: Outlet plug covers are not permitted.

Corrections To Be Made:

Rooms 124 and 125 do not have self-closing or tamper resistant electrical outlets covers.

The electrical outlets in these rooms need to have self-closing or tamper resistant electrical outlets.

Correction: Self-closing electrical outlet covers were added to the electrical outlets in rooms 124 & 125.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

09/01/2024

Status: **Corrected**

Actual
Completion
Date:

08/30/2024

Emily Moser

Provider Signature

08/06/2024

Date

Clint Rux

Inspector Signature

08/06/2024

Date