

# Facility Safety Inspection Fire & Life Safety / Environmental Health Before & After School Center - School Location Compliance Plan

Provider's Name: **Great After School Place - Medary Elementary**

City: **Brookings**

Provider Number: **011508868**

Inspector: **Charles Schmidt**

Date of Inspection: **10/03/2022**

Time of Inspection: **3:59 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

4. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

<p>Corrections To Be Made:</p> <p><b>Exit lights/Emergency Flood lights failed back up test in adjacent gymnasium at time of inspection.</b></p> <p><b>Correction: Verification received that exit lights and other lights are all functional.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table border="0"> <tr> <td style="padding-right: 20px;">Suggested Completion Date:</td> <td>Actual Completion Date:</td> </tr> <tr> <td style="padding-right: 20px;"><b>11/03/2022</b></td> <td><b>11/10/2022</b></td> </tr> <tr> <td colspan="2">Status: <b>Corrected</b></td> </tr> </table>	Suggested Completion Date:	Actual Completion Date:	<b>11/03/2022</b>	<b>11/10/2022</b>	Status: <b>Corrected</b>	
Suggested Completion Date:	Actual Completion Date:						
<b>11/03/2022</b>	<b>11/10/2022</b>						
Status: <b>Corrected</b>							

**Nicole**

\_\_\_\_\_  
Provider Signature

**10/03/2022**

\_\_\_\_\_  
Date

**Charles Schmidt**

\_\_\_\_\_  
Inspector Signature

**10/03/2022**

\_\_\_\_\_  
Date