

# Facility Safety Inspection Fire & Life Safety / Environmental Health Before & After School Center - School Location Compliance Plan

Provider's Name: **Great After School Place - Hillcrest Elementary**

City: **Brookings**

Provider Number: **011512104**

Inspector: **Charles Schmidt**

Date of Inspection: **10/03/2022**

Time of Inspection: **4:36 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

4. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

Corrections To Be Made:	Agency Action:	
<b>Exit and emergency lights in areas of the school utilized by program failed back up testing.</b>	<b>Compliance Plan</b>	
<b>Correction: Verification received that lights have been replaced and are operational.</b>	Suggested Completion Date:	Actual Completion Date:
	<b>11/03/2022</b>	<b>11/29/2022</b>
	Status: <b>Corrected</b>	

**Abby**

Provider Signature

**10/03/2022**

Date

**Charles Schmidt**

Inspector Signature

**10/03/2022**

Date