

# Facility Safety Inspection Fire & Life Safety / Environmental Health Before & After School Center - Non-School Location Compliance Plan

Provider's Name: **SDSU OST Program**

City: **Brookings**

Provider Number: **011515519**

Inspector: **Charles Schmidt**

Date of Inspection: **04/24/2023**

Time of Inspection: **2:55 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

14. Is electrical system being used properly? 61:15:01 NOTE: Check for overloads or frayed extension cords.

<p>Corrections To Be Made:</p> <p><b>The microwave in 120B needs to be plugged directly into a wall outlet. It is currently plugged into a hanging, unsecured power strip.</b></p> <p><b>Correction: Microwave was moved to another area to be plugged directly into an electrical outlet.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table border="0"> <tr> <td>Suggested Completion Date:</td> <td>Actual Completion Date:</td> </tr> <tr> <td><b>04/24/2023</b></td> <td><b>04/24/2023</b></td> </tr> </table> <p>Status: <b>Corrected Immediately</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>04/24/2023</b>	<b>04/24/2023</b>
Suggested Completion Date:	Actual Completion Date:				
<b>04/24/2023</b>	<b>04/24/2023</b>				

## C. FOOD SERVICE

83. If a home-style dishwasher is used, does it have a hot water sanitizing cycle with water reaching 150 degrees F and the sanitizing cycle runs to completion without interruption? 67:42:11:07

Corrections To Be Made:

**Sanitizing cycle not selected at time of inspection when wash cycle was running.**

**Correction: Staff person was made aware and will ensure the sanitizing button is always selected prior to cycle starting.**

Agency Action:

**Compliance Plan**

Suggested  
Completion  
Date:

Actual  
Completion  
Date:

**04/24/2023**

**04/24/2023**

Status: **Corrected Immediately**

**Jen Johnson**

Provider Signature

**04/24/2023**

Date

**Charles Schmidt**

Inspector Signature

**04/24/2023**

Date