

# Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **SDSU Laboratoy Preschool**

City: **Brookings**

Provider Number: **011515520**

Inspector: **Charles Schmidt**

Date of Inspection: **04/24/2023**

Time of Inspection: **2:52 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

13. In areas providing access to exits, do combustible decorations cover less than 10% of the wall area?  
61:15:05:05

Corrections To Be Made:	Agency Action:	
<b>Items placed on display panels exceed 10% coverage requirements.</b>	<b>Compliance Plan</b>	
<b>In areas providing access to exits, no more than 10% of the walls may be covered with decorations.</b>	Suggested Completion Date:	Actual Completion Date:
<b>Correction: Posters removed from panel area.</b>	<b>04/30/2023</b>	<b>04/30/2023</b>
	Status: <b>Corrected</b>	

**Jen Johnson**

Provider Signature

**04/24/2023**

Date

**Charles Schmidt**

Inspector Signature

**04/24/2023**

Date